

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3775-1519:100

Page 1 of 1

CATEGORY: Manual Locks

LISTEE: Securitech Group Inc., 54-45 44th Street, Maspeth, NY 11378
Contact: *Mark J. Berger (718) 392-9000

DESIGN: Models 4921, 4922, 4923, 4931, 4932, 4933, 4934, 4935P and 4945 manual exit locks. Units may be followed by one or two suffix numbers. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 101 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual exit locks for use on non-fire rated single or double outwardly doors where permitted per code to prevent unauthorized entry. Authority having jurisdiction shall be consulted prior to installation.

NOTE: **NOT** approved for use in-lieu of the required panic hardware.

*Rev. 06-06-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 18, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager